



Buffalo Owner's Association
c/o Lene' Simnioniw
P.O. Box 740511
Arvada CO 80006

Phone: 303-405-7510
Fax:

Sample Identification

Lab ID Number: CC100-148
Report Date: 06/08/2007 Time: 10:24
Name:
Address: The Buffalo Subdivision
"External Spring"
City: Jefferson?
State: CO Zip:
County: Park
Date Collected: 06/06/2007 Time: 15:05
Date Received: 06/07/2007
Sampled By: DB

Type of System

PWSID#:
Chlorine Residual:
Private Well?: Y
Other: Y
Disinfected?: N Date:
Type: Routine Sample
Payment: Invoice

Laboratory Test Results

for property at: The Buffalo Subdivision

Potability

Type of Test: P/A

Total Coliforms per 100 mls: Absent

Fecal Coliforms per 100 mls: Absent

This potability sample PASSES

Notes

Analyst: Kelly O'Brien

Buffalo Owner's Association
c/o Lene' Simnioniw

P.O. Box 740511
Arvada CO 80006

Lab ID Number: CC100-148

Date Collected: 06/06/2007 Time: 15:05

for property at: The Buffalo
Subdivision

"External Spring"

Phone: 303-405-7510 Fax:

Payment: Invoice

*Within
Acceptable
Range*

	<i>Test</i>	<i>Value</i>	<i>Within Acceptable Range</i>	<i>State MCL</i>	<i>Unreg. 2nd</i>
<i>Laboratory "Wet Chemistry" Test Results</i>	Nitrate	1.0 mg/L	YES	10. mg/L	none
	Copper	mg/L		1.3 mg/L	none
	Fluoride	mg/L		4.0 mg/L	2.0 mg/L
	Hardness	gp/g		none	10. gp/g
	Iron	mg/L		none	0.3 mg/L
	TDS	mg/L		none	500. mg/L
	pH	S.U.		none	7.0 S.U.
	Chromium	mg/L		0.1 mg/L	none
	Zinc	mg/L		none	5. mg/L
	Manganese	mg/L		none	0.05 mg/L
	Sulfate	mg/L		none	250. mg/L
	Silica	mg/L		none	none
	Alkalinity	mg/L		none	none
	Tannin	mg/L		none	none
	Surfactants	mg/L		none	0.5 mg/L
	Phosphates	mg/L		none	none
	Other				
	Analyst: KEO				

Notes: