



C.A.S. (Buffalo Owners Assoc.)  
Attn: Jim Just  
14142 Denver West Pkwy, St#350  
Lakewood CO 80401

Phone: 877-861-9331

Fax: Email

**Sample Identification**

Lab ID Number: GD029-687  
Report Date: 05/18/2009 Time: 9:45  
Name: "Eternal Spring"  
Address: Buffalo Owners Park  
Spring Water Thorough  
Pipe  
City:  
State: CO Zip:  
County: Park  
Date Collected: 05/15/2009 Time: 12:30  
Date Received: 05/15/2009  
Sampled By: J.J

**Type of System**

PWSID#:  
Chlorine Residual:  
Private Well?: Y  
Other: N  
Disinfected?: N Date:  
Type: Routine Sample  
Payment: Invoiced

**Laboratory Test Results**

for property at: Buffalo Owners Park

**Potability**

Type of Test: P/A

Total Coliforms per 100 mls: Absent

Fecal Coliforms per 100 mls: Absent

**This potability sample PASSES**

**Notes**

Analyst: Scott A. Verrill

C.A.S. (Buffalo Owners Assoc.)  
Attn: Jim Just  
14142 Denver West Pkwy, St#350  
Lakewood CO 80401

Lab ID Number: GD029-687  
Date Collected: 05/15/2009 Time: 12:30  
for property at: Buffalo Owners Park  
Spring Water  
Thorough Pipe  
Phone: 877-861-9331 Fax: Email

Payment: Invoiced

*Within  
Acceptable*

	<i>Test</i>	<i>Value</i>	<i>Range</i>	<i>State MCL</i>	<i>Unreg. 2nd</i>	
<b>Laboratory</b> <b>"Wet Chemistry"</b> <b>Test Results</b>	Nitrate	0.8 mg/L	YES	10. mg/L	none	
	Copper	mg/L		1.3 mg/L	none	
	Fluoride	mg/L		4.0 mg/L	2.0 mg/L	
	Hardness	gp/g		none	10. gp/g	
	Iron	mg/L		none	0.3 mg/L	
	TDS	mg/L		none	500. mg/L	
	pH	S.U.		none	7.0 S.U.	
	Chromium	mg/L		0.1 mg/L	none	
	Zinc	mg/L		none	5. mg/L	
	Manganese	mg/L		none	0.05 mg/L	
	Sulfate	mg/L		none	250. mg/L	
	Silica	mg/L		none	none	
	Alkalinity	mg/L		none	none	
	Tannin	mg/L		none	none	
	Surfactants	mg/L		none	0.5 mg/L	
	Phosphates	mg/L		none	none	
	Other					
	Analyst: Scott A. Verrill					

**Notes:**